



TEST REPORT



Report No :URS/M/RID/24/2/3003			
Dated : 14/02/2024			
Issued To : Purunity purification devices trading LLC		Dubai- UAE Site: Head Office - Tecom	
Attention	Suraj Rajan		
Sample Condition(Receipt Temperature)	4.0°C	Sample Condition (On Site)	19.2°C
Customer Ref.No.	55912/ Dated 10/02/2024 Trf No.URS/SR/51018 / Sample ID: URS/F/M/SID/24 /2/2175	Sample Package & Quantity	500 ML
Sample Name	Water: Drinking – Micro – CHP -6200N	Sampled by	Ali
Sample description	Colorless Liquid	Delivered by	Lab Representative
Batch No. /Lot No.	NA	Sampling Protocol	URS-SOP-16
Manufacturing Date	NA	Date of Sample Receipt	10/02/2024
Best before date	NA	Date of Analysis	10/02/2024
Other Details	NA	Date of Completion	14/02/2024

Note: The submitted samples are Drawn by the Laboratory.

Note: For any queries, please contact lab manager at labmanager@urslabs.com.

S.NO	Parameters	Unit	Test Method	Result	LPS: ACCEPTABLE LIMIT Food safety department- External circular (DM-FSD-CR01)
1	Heterotrophic Plate Count	Cfu/ml	APHA 23 EDITION 2017, 9215 B	<1	-
2	E.Coli	MPN/100ml	APHA 23 EDITION 2017, 9221B, 9221 E	Absent	Absent
3	Pseudomonas aeruginosa	MPN/100ml	APHA 23 EDITION 2017, 9213 F	Absent	Absent
4	Coliform	Cfu/100ml	APHA 23 EDITION 2017, 9221 B, 9221C, 9221 E	Absent	Absent

Remarks: The sample analysed is satisfactory quality with respect to the above tested parameters and limit of specifications. **Decision Rule:** Statements of conformity (e.g. Satisfactory/ Not Satisfactory) to specifications are made in this report without taking measurement uncertainty into account. Where statements of conformity are made in this report, the following decision rules(Simple acceptance rule) are applied: **Satisfactory – Results within limits/specifications, Not Satisfactory – Results exceed limits/specifications. Test method Variation:** None

Key words:

CFU –Colony forming Unit, ND-Not detected, EAPC-Estimated aerobic plate count, LPS-Limits as per standard, BAM – Bacteriological Analytical Manual, CMMEF-Compendium of methods for the Microbiological examination of foods. APHA-American public health association-Standard method for the examination of water and waste water 22 edition: 2012

Note: (1) The results relate only to the items tested, (2) The test report shall not be reproduced except in full without the written approval of the URS laboratory, (3) For details of the accredited scope, please contact laboratory or accreditation body website

Nidhila

Nidhila Ganga
Technical Manager- Microbiology

URS Testing Laboratory LLC
PO Box 377913
Tel : +971 48837115
E-Mail : info@urslabs.com
Web site : www.urslabs.com



-----END OF THE TEST REPORT-----